



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ  
Dilovası OSB Mahallesi Fırat Caddesi No: 18  
Dilovası, Koçaeli / TÜRKİYE  
www.effectis.com

## DECLARATION OF TEST RESULTS

No: EEA – 2000 – 0119 –Rev1

The fire resistance test was carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 09.09.2020 in accordance with the test standard:

**UL 10C:2016**

**“DS-HSD-ID-EMK-1000-24”**

High Security Steel Door with Electromechanical Motor

FIRE RESISTANCE CLASSIFICATION	
Direction : Opening into the fire	
Fire Endurance	90 minutes
Hose Stream	Passed

Placed on the market by: İD MÜHENDİSLİK İRFAN DURSUN  
Büyükşehir Mah. Hüseyin Yıldız Sok. No:7 A-11 Blok D.2  
Beylikdüzü, İSTANBUL /TURKEY

Manufactured by: DORUKSAFE YÜKSEK GÜVENLİKLİ KAPI SİSTEMLERİ SAN. VE TİC.  
LTD. ŞTİ.  
Cevizli Mah. Zuhâl Cad. A6 Blok No:46 F D:46  
Maltepe,İSTANBUL/TURKEY

Ali BAYRAKTAR  
Laboratory Manager  
11.01.2022

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report RFTR20229.





EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ  
Dilovası OSB Mahallesi Fırat Caddesi No: 18  
Dilovası, Kocaeli / TÜRKİYE  
www.effectis.com

## TEST SONUÇ BELGESİ

No: EEA – 2000 – 0119 – Rev1

Aşağıda tanımlanan ürünlerin yangına dayanım testi Efectis Era Avrasya Test Laboratuvarı'nda 09.09.2020 tarihinde belirtilen standart kapsamında gerçekleştirilmiştir:

**UL 10C:2016**

**“DS-HSD-ID-EMK-1000-24”**

Elektromekanik Motor Kilitli Yüksek Güvenlikli Çelik Kapı

YANGINA DAYANIM SINIFI	
Çalışma yönü: Alev içine doğru açılan	
Yangına Dayanım	90 dakika
Hortumla Su Akışı	Geçti

Piyasaya süren firma:

İD MÜHENDİSLİK İRFAN DURSUN  
Büyükşehir Mah. Hüseyin Yıldız Sok. No:7 A-11 Blok D.2  
Beylikdüzü, İSTANBUL /TÜRKİYE

Üretici firma:

DORUKSAFE YÜKSEK GÜVENLİKLİ KAPI SİSTEMLERİ SAN. VE TİC.  
LTD. ŞTİ.  
Cevizli Mah. Zuhul Cad. A6 Blok No:46 F D:46  
Maltepe,İSTANBUL/TÜRKİYE

Ali BAYRAKTAR  
Laboratuvar Müdürü  
11.01.2022

Bu belge, test sonuçlarının bir beyanıdır ve ürünün tip onayını veya belgelendirmesini temsil etmez. Ürün özellikleri ve uygulama alanı ile ilgili tüm detayları RFTR20229 No.lu raporda tanımlanmıştır.





EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ  
Dilovası OSB Mahallesi Fırat Caddesi No: 18  
Dilovası, Kocaeli / TÜRKİYE  
www.effectis.com

## DECLARATION OF TEST RESULTS

No: EEA – 2000 – 0164 – Rev1

The fire resistance test was carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 23.12.2020 in accordance with the test standard:

**UL 10B:2020**

**“DS-FPD-230x135-ID-EMK-1000-24”**

High Security Steel Door with Electromechanical Motor


FIRE RESISTANCE CLASSIFICATION	
Direction : Opening away from the fire	
Fire Endurance	180 minutes
Hose Stream	Passed

Placed on the market by: İD MÜHENDİSLİK İRFAN DURSUN  
Büyükşehir Mah. Hüseyin Yıldız Sok. No:7 A-11 Blok D.2  
Beylikdüzü, İSTANBUL / TURKEY

Manufactured by: DORUKSAFE YÜKSEK GÜVENLİKLİ KAPI SİSTEMLERİ SAN. VE TİC.  
LTD. ŞTİ  
Cevizli Mah. Zuhal Cad. A6 Blok No:46 F D:46  
Maltepe, İSTANBUL / TURKEY

Ali BAYRAKTAR  
Laboratory Manager  
11.01.2022

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report RFTR20322.





EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ  
Dilovası OSB Mahallesi Fırat Caddesi No: 18  
Dilovası, Koçaeli / TÜRKİYE  
www.effectis.com

## TEST SONUÇ BELGESİ

No: EEA - 2000 - 0164 - Rev1

Aşağıda tanımlanan ürünlerin yangına dayanım testi Efectis Era Avrasya Test Laboratuvarı'nda 23.12.2020 tarihinde belirtilen standart kapsamında gerçekleştirilmiştir:

**UL 10B:2020**

**"DS-FPD-230x135-ID-EMK-1000-24"**  
Elektromekanik Motor Kilitli Yüksek Güvenlikli Metal Kapı

YANGINA DAYANIM SINIFI	
Çalışma yönü: Alevden dışarı doğru açılan	
Yangına Dayanım	180 dakika
Hortumla Su Akışı	Geçti

Piyasaya süren firma:

İD MÜHENDİSLİK İRFAN DURSUN  
Büyükşehir Mah. Hüseyin Yıldız Sok. No:7 A-11 Blok D.2  
Beylikdüzü, İSTANBUL /TÜRKİYE

Üretici firma:

DORUKSAFE YÜKSEK GÜVENLİKLİ KAPI SİSTEMLERİ SAN. VE TİC.  
LTD. ŞTİ.  
Cevizli Mah. Zuhul Cad. A6 Blok No:46 F D:46  
Maltepe,İSTANBUL/TÜRKİYE

Ali BAYRAKTAR  
Laboratuvar Müdürü  
11.01.2022

Bu belge, test sonuçlarının bir beyandır ve ürünün tip onayını veya belgelendirmesini temsil etmez. Ürün özellikleri ve uygulama alanı ile ilgili tüm detayları RFTR20322 No.lu raporda tanımlanmıştır.

